



DEPARTMENT OF INDUSTRIAL CHEMISTRY

ALIGARH MUSLIM UNIVERSITY, ALIGARH

औद्योगिक रसायन विभाग, अलीगढ़ मुस्लिम विश्वविद्यालय


شعبہ انڈسٹریل کیمسٹری، علی گڑھ مسلم یونیورسٹی


D.No: 2049/Ind.Chem.

Dated: 5th May, 2026

The Principal
The Blossoms School
Muzammil Manzil, Civil Lines
Aligarh

The water sample from your school has been successfully tested at the Department of Industrial Chemistry AMU Aligarh. All analyses were conducted strictly in accordance with the latest APHA 2022 standards to ensure accuracy and reliability. The complete test report, detailing all parameters and results, is enclosed herewith for your review and necessary action.


Dr. Mohammad Zain Khan
Lab Incharge & Assistant Professor
Department of Industrial Chemistry
AMU Aligarh


Dr. Shahab Ali Asghar Nami
Chairman & Associate Professor
Department of Industrial Chemistry
AMU Aligarh

The Blossoms School

Principal





DEPARTMENT OF INDUSTRIAL CHEMISTRY
ALIGARH MUSLIM UNIVERSITY, ALIGARH

औद्योगिक रसायन विभाग, अलीगढ़ मुस्लिम विश्वविद्यालय

شعبہ الائنڈ انڈسٹریل کیمسٹری، اعلیٰ کالج، اعلیٰ کالج، اعلیٰ کالج، اعلیٰ کالج

D.No:

Dated: 5th May, 2026

Water Quality Analysis Report

Test Sample- The Blossoms School, Aligarh

S. No.	Drinking Water Parameters	Concentration (mg/L)	IS: 10500* permissible limit (ppm)	WHO permissible limit (ppm)
1.	Chloride	50	<250	200-600
2.	Fluoride	0.4	0.6-1.2	0.6-1.5
3.	Alkalinity	360	200-600	200-600
4.	Iron	0.046	0.3	0.3
5.	pH	7.7	6.5-8.5	6.5-8.5
6.	TDS	640	500-1500	500-1500
7.	SS	60	<100	<100
8.	Conductivity	1140	300-1500	300-1500

* Indian Standard Specifications for Drinking Water

--XXX--

The Blossoms School
Principal

